

light fixture upgrade or replacement

ALL CURRENT FIXTURES CONTAINING T12 LAMPS AND MAGNETIC BALLASTS NEED TO BE REPLACED BY ELECTRONIC BALLASTS AND T8 LAMPS AS SOON AS POSSIBLE.



The U.S. Department of Energy has phased out fluorescent T12 lamps and ballasts in favor of T8 technology. The state-of-the-art T8 technology makes building electricity usage 40% more efficient, offers a more natural light color, and reduces the flicker noise associated with T12 components.

Departmental fixtures in fume hoods, under-counter lights, cold rooms, etc., are candidates for a lighting upgrade or replacement.

Contact the Service Office (217-333-0340) concerning a WO or estimate as soon as possible. T12 Light fixtures will be obsolete once dwindling supplies are exhausted.



Updated 10/11/2013

Facilities & Services
PLAN ■ BUILD ■ MAINTAIN ■ SERVE

